
CERTIFICATE OF APPROVAL

No CF 758

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

Accent Hansen Limited
Cedar House, Sandbrook Business Park, Rochdale, OL11 1LQ
Tel: 0161 284 4100 Fax: 0161 655 3119

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

'FireShield', 'SecureShield 2'
and 'Soundshield 35' Honeycomb
Cored Steel Doors

TECHNICAL SCHEDULE

TS12 Hinged or Pivoted Fire
Resisting Pedestrian Type
Doorsets with Metallic Leaves
and Frames

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager

Issued: 12 July 2011
Reissued: 22nd November 2018
Valid to: 21st November 2023



CERTIFICATE No CF 758
ACCENT HANSEN LIMITED

FireShield, SecureShield 2 and SoundShield 35 Honeycomb Cored Steel Doors

1. This approval relates to the use of the above doorsets in providing fire resistance of up to 120 minutes integrity as defined in BS EN 1634-1: 2000. Subject to the undermentioned conditions, the doors will meet the relevant requirements of BS 9999 for fire resisting doorsets, for periods of up to 120 minutes (dependant upon design limitations) when used in accordance with the provisions therein.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS12
 - iii) A design appraisal against TS12
 - iv) Inspection and surveillance of factory production control
 - v) Certification of quality management system to ISO 9001: 2008.
4. The doorsets comprise door leaves with metallic leaves, for use with metallic frames (code MM).
5. This approval is applicable to complete doorsets only.
6. This approval is applicable to single-acting, single and double-leaf, latched MM doorsets at leaf dimensions up to those given in Tables 1 and 2.
7. Hardware items, including closing devices, shall be CERTIFIRE approved for use with metal (MM) doorsets or otherwise as specified in the data sheet.
8. The doorsets shall be mechanically fixed to wall constructions having a fire resistance of at least the same period as the doorset.
9. This certificate does not include any approval relating to the mechanical requirements of the doorsets specified in TS 12.
10. Labels to the CERTIFIRE design referencing Accent Hansen Ltd., CERTIFIRE and CERTIFIRE Ref. No. CF 758 and the relevant fire resistance shall be affixed to each door in the prescribed position.

CERTIFICATE No CF 758 ACCENT HANSEN LIMITED

FireShield, SecureShield 2 and Soundshield 35 Honeycomb Cored Steel Doors

Zintec Mild Steel Doorsets

Table 1: Maximum Permissible Door Leaf Dimensions for Latched,
Double-Leaf, Unglazed Doorsets with Astragal

Integrity (mins)	Max. Height (mm)	Max. Width (mm)	Subject to Max. Leaf Area (m ²)
30/60/90/120	3045 (at 985 wide)	1235 (at 2429 high)	3.00

Table 2: Maximum Permissible Door Leaf Dimensions for Latched,
Single-Leaf, Glazed or Unglazed Doorsets

Integrity (mins)	Max. Height (mm)	Max. Width (mm)	Subject to Max. Leaf Area (m ²)
30/60/90/120	3162 (at 939 wide)	1223 (at 2428 high)	2.97

11. This approval relates to on going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number and application where appropriate.